CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.04/CSR-01-240c/CEMENT/2016-17 Date: 10.01.2017

TEST REPORT ON CEMENT

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of Work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Sample ID	:	Cement – Sample 3
Sample Received on	:	07.01.2017
Period of Testing	:	07.01.2017 to 10.01.2017

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988 (RA-2014)	30.00 %	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988 (RA-2014)	165 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988 (RA-2014)	490 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988 (RA-2014)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

Civil-Tech Consultants & Engineers Bangalore

AE W4 10/1

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.04/CSR-01-240c/SAND-Gradation/2016-17 10.01.2017

TEST REPORT ON SIEVE ANALYSIS OF FINE AGGREGATES

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of Work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Sample ID	:	Fine Aggregates - Sample 3
Technical Reference	:	IS : 2386 (Part 1) - 1963 (RA-2011)
Sample Received On	:	07.01.2017
Date of Testing	:	10.01.2017

Total Wt. of Aggregates in gms = **1000**

IS Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2011)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	96.30	90-100	90-100	90-100	95-100
2.36	78.80	60-95	75-100	85-100	95-100
1.18	57.20	30-70	55-90	75-100	90-100
600 Micron	28.20	15-34	35-59	60-79	80-100
300 Micron	13.20	5-20	8-30	12-40	15-50
150 Micron	5.00	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Remarks : This sample is under Zone-I specific limits.

Civil-Tech Consultants & Engineers Bangalore

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

AE W4 10/1

****

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.04/CSR-01-240c/AGG/GR/2016-17

10.01.2017

TEST REPORT ON SIEVE ANALYSIS OF COARSE AGGREGATES

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of Work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Sample ID	:	Coarse Aggregates (40mm) - Sample 3
Technical Reference	:	IS : 2386 (Part 1) -1963 (RA-2016)
Sample Received on	:	07.01.2017
Date of Testing	:	10.01.2017

Total Wt. of Aggregates in gms= **5000**

IS Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2016)	
		Graded	Single Sized
80	100	100	-
63	100	-	100
40	97.60	95-100	85-100
20	37.60	30-70	0-20
10	13.30	10-35	0-5
4.75	1.34	0-5	-

* Information is furnished by the Customer/Representative

Remarks : This sample is under graded specific limits.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

AE W4 10/1

****

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory
An ISO 9001:2008 Certified Company
NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

Job No.: CTCE/BBMP/KRIDL/W.No.04/Steel/2016-17 10.01.2017

TEST REPORT ON REINFORCEMENT STEEL

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Samples ID	:	12 mm Bar
Technical Reference	:	IS: 1786-2008
Date of Testing	:	10.01.2017

Sl No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm2	Tensile strength (Ultimate stress) N/mm2	Elongation percent gauge length		
1	12	0.89	517	519	13.55	O.K	O.K

*Information is furnished by the Customer/Representative.

Civil-Tech Consultants & Engineers Bangalore

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

AE W4
10/1

Civil-tech Consultants & Engineers
#23/14, 7th Cross, 3rd Stage, 4th Block,
Shakthi Ganapathinagar,
Basaveshwaranagar, Bangalore-560 079.

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.04/CSR-01-240c/Cube/2016-17

10.02.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of the work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Sample ID	:	Drain Concrete
Technical Reference	:	IS: 516-1959 (RA-2013)
Size of cubes	:	150mmx150mmx150mm
Cross Sectional Area	:	22500 mm^2
* Grade of Concrete	:	M_{20}
Compressive Strength as on	:	28^{th} day
Sample Received on	:	10.02.2017

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	13.01.2017	10.02.2017	8.227	479.8	21.32
2	13.01.2017	10.02.2017	8.378	508.2	22.59
3	13.01.2017	10.02.2017	8.419	510.7	22.70

*Information is furnished by the Customer/Representative.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

AE W4 10/2

****

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.04/CSR-01-240c/Cube/2016-17

18.02.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of the work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Sample ID	:	Pavement Concrete
Technical Reference	:	IS: 516-1959 (RA-2013)
Size of cubes	:	150mmx150mmx150mm
Cross Sectional Area	:	22500 mm^2
* Grade of Concrete	:	M_{20}
Compressive Strength as on	:	28^{th} day
Sample Received on	:	18.02.2017

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	21.01.2017	18.02.2017	8.100	507.4	22.55
2	21.01.2017	18.02.2017	8.226	516.5	22.96
3	21.01.2017	18.02.2017	8.392	529.8	23.55

*Information is furnished by the Customer/Representative.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

AE 4 18/2

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.04/CSR-01-240c/Cube/2016-17

18.02.2017

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

* Customer	:	**Asst. Executive Engineer,** Yelahanka Satellite Town Sub Division, BBMP, Bangalore.
* Agency	:	**Technical Manager,** KRIDL, Bangalore.
* Name of the work	:	Construction of concrete drains & concrete roads at Ambedkar Nagar in Ward No.04, BBMP, Bangalore.
* Reference	:	BBMP/EE(YNK.D)/W.O/106/2016-17 Dated: 07.01.2017
* Sample ID	:	Pavement Concrete
Technical Reference	:	IS: 516-1959 (RA-2013)
Size of cubes	:	150mmx150mmx150mm
Cross Sectional Area	:	22500 mm^2
* Grade of Concrete	:	M_{20}
Compressive Strength as on	:	28^{th} day
Sample Received on	:	18.02.2017

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	21.01.2017	18.02.2017	8.205	502.2	22.32
2	21.01.2017	18.02.2017	8.337	514.7	22.88
3	21.01.2017	18.02.2017	8.428	527.9	23.46

*Information is furnished by the Customer/Representative.

Note:

⇒The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒Any Query regarding the report must be reported within 30 days from the date of testing.

****

AE W4 18/2

VIDYARANI P.K.
Technical Manager

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com